


**Суточный график нагрузок ГПП-1 110/6 кВ за 15.06.2022**  
**ООО "ЭСР"**

Ячейка	Часы																							
	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23
<b>секция 1А</b>	<b>Нагрузка, А</b>																							
U, кВ	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1
яч.48 ввод Т-1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Р, кВт	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Q, кВАр	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
яч.3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
яч.4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
яч.5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
яч.6	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
яч.7	0	0	0	0	0	0	0	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5
Р, кВт	0	0	0	0	0	0	0	45	45	45	45	45	45	45	45	45	45	45	45	45	45	45	45	45
Q, кВАр	0	0	0	0	0	0	0	28	28	28	28	28	28	28	28	28	28	28	28	28	28	28	28	28
яч.8	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
яч.10	0	0	0	0	0	0	0	10	10	10	10	10	10	10	10	0	0	0	0	0	0	0	0	0
Р, кВт	0	0	0	0	0	0	0	90	90	90	90	90	90	90	90	0	0	0	0	0	0	0	0	0
Q, кВАр	0	0	0	0	0	0	0	56	56	56	56	56	56	56	56	0	0	0	0	0	0	0	0	0
яч.12	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Р, кВт	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Q, кВАр	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
<b>секция 1Б</b>																								
яч.41 ввод Т-1	100	100	100	100	100	100	100	600	250	800	150	150	200	200	200	200	150	150	150	100	100	100	100	100
Р, кВт	898	898	898	898	898	898	898	5388	2245	7185	1347	1347	1796	1796	1796	1796	1347	1347	1347	898	898	898	898	898
Q, кВАр	557	557	557	557	557	557	557	3339	1391	4453	835	835	1113	1113	1113	1113	835	835	835	557	557	557	557	557
яч.44	10	20	40	30	30	40	20	30	60	40	40	40	40	40	40	40	40	40	40	30	30	40	40	40
Р, кВт	90	180	359	269	269	359	180	269	539	359	359	359	359	359	359	359	359	359	359	269	269	359	359	359
Q, кВАр	56	111	223	167	167	223	111	167	334	223	223	223	223	223	223	223	223	223	223	167	167	223	223	223
яч.45	0	0	0	0	0	0	0	100	120	100	40	40	100	100	100	120	40	60	60	40	40	20	20	20
Р, кВт	0	0	0	0	0	0	0	898	1078	898	359	359	898	898	898	1078	359	539	539	359	359	180	180	180
Q, кВАр	0	0	0	0	0	0	0	557	668	557	223	223	557	557	557	668	223	334	334	223	223	111	111	111
яч.46	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30	30
Р, кВт	269	269	269	269	269	269	269	269	269	269	269	269	269	269	269	269	269	269	269	269	269	269	269	269
Q, кВАр	167	167	167	167	167	167	167	167	167	167	167	167	167	167	167	167	167	167	167	167	167	167	167	167
яч.1	0	0	0	0	0	0	0	400	0	600	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Р, кВт	0	0	0	0	0	0	0	3592	0	5388	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Q, кВАр	0	0	0	0	0	0	0	2226	0	3339	0	0	0	0	0	0	0	0	0	0	0	0	0	0
<b>секция 2А</b>																								
яч. 32 ввод Т-2	0	1000	800	900	800	900	900	600	600	600	600	0	600	600	1200	0	600	1200	600	0	0	600	0	600
Р, кВт	0	8981	7185	8083	7185	8083	8083	5388	5388	5388	5388	0	5388	5388	10777	0	5388	10777	5388	0	0	5388	0	5388

Q, кВАр	0	5566	4453	5009	4453	5009	5009	3339	3339	3339	3339	0	3339	3339	6679	0	3339	6679	3339	0	0	3339	0	3339
яч.16	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
P, кВт	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Q, кВАр	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
яч.18	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
яч.19	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
яч.20	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
яч.21	0	1000	0	900	800	0	900	0	600	600	600	0	600	600	600	0	0	600	600	0	0	0	0	0
P, кВт	0	8981	0	8083	7185	0	8083	0	5388	5388	5388	0	5388	5388	5388	0	0	5388	5388	0	0	0	0	0
Q, кВАр	0	5566	0	5009	4453	0	5009	0	3339	3339	3339	0	3339	3339	3339	0	0	3339	3339	0	0	0	0	0
яч.22	0	0	800	0	0	900	0	600	0	0	-	-	-	0	600	0	600	600	0	0	0	600	0	600
P, кВт	0	0	7185	0	0	8083	0	5388	0	0	-	-	-	0	5388	0	5388	5388	0	0	0	5388	0	5388
Q, кВАр	0	0	4453	0	0	5009	0	3339	0	0	-	-	-	0	3339	0	3339	3339	0	0	0	3339	0	3339
<b>секция 2Б</b>																								
яч. 38 ввод Т-2	100	100	1000	100	250	250	100	800	350	350	800	300	850	300	300	800	300	300	800	150	150	800	150	300
P, кВт	898	898	8981	898	2245	2245	898	7185	3143	3143	7185	2694	7634	2694	2694	7185	2694	2694	7185	1347	1347	7185	1347	2694
Q, кВАр	557	557	5566	557	1391	1391	557	4453	1948	1948	4453	1670	4731	1670	1670	4453	1670	1670	4453	835	835	4453	835	1670
яч.28	0	0	0	0	0	0	0	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
P, кВт	0	0	0	0	0	0	0	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90
Q, кВАр	0	0	0	0	0	0	0	56	56	56	56	56	56	56	56	56	56	56	56	56	56	56	56	56
яч.29	0	0	0	0	0	0	0	10	10	10	5	5	5	5	5	5	5	5	5	5	5	5	5	5
P, кВт	0	0	0	0	0	0	0	90	90	90	45	45	45	45	45	45	45	45	45	45	45	45	45	45
Q, кВАр	0	0	0	0	0	0	0	56	56	56	28	28	28	28	28	28	28	28	28	28	28	28	28	28
яч.30	0	0	0	0	0	0	0	10	50	50	10	10	10	10	10	10	10	10	10	10	10	10	10	10
P, кВт	0	0	0	0	0	0	0	90	449	449	90	90	90	90	90	90	90	90	90	90	90	90	90	90
Q, кВАр	0	0	0	0	0	0	0	56	278	278	56	56	56	56	56	56	56	56	56	56	56	56	56	56
яч.31	0	0	0	0	0	0	0	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5	5
P, кВт	0	0	0	0	0	0	0	45	45	45	45	45	45	45	45	45	45	45	45	45	45	45	45	45
Q, кВАр	0	0	0	0	0	0	0	28	28	28	28	28	28	28	28	28	28	28	28	28	28	28	28	28
яч.33	70	70	70	50	70	70	70	50	70	80	50	50	80	60	60	60	50	50	60	60	60	60	60	60
P, кВт	629	629	629	449	629	629	629	449	629	718	449	449	718	539	539	539	449	449	539	539	539	539	539	539
Q, кВАр	390	390	390	278	390	390	390	278	390	445	278	278	445	334	334	334	278	278	334	334	334	334	334	334
яч.34	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10
P, кВт	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90	90
Q, кВАр	56	56	56	56	56	56	56	56	56	56	56	56	56	56	56	56	56	56	56	56	56	56	56	56
яч.35	0	10	800	0	150	150	0	600	150	150	600	150	650	150	150	600	150	150	600	0	0	600	0	150
P, кВт	0	90	7185	0	1347	1347	0	5388	1347	1347	5388	1347	5837	1347	1347	5388	1347	1347	5388	0	0	5388	0	1347
Q, кВАр	0	56	4453	0	835	835	0	3339	835	835	3339	835	3618	835	835	3339	835	835	3339	0	0	3339	0	835

Генеральный директор




А.К. Шаварин

Замеры напряжения и нагрузок на ГПП-1 за 15.06.2022

ООО "ЭСР"

Часы	Трансформатор-1				Трансформатор-2				Нагрузка, кВт			
	I вн, А	I нн, А	U вн, кВ	U нн, В	I вн, А	I нн, А	U вн, кВ	U нн, В	яч.32	яч.38	яч.41	яч.48
0	0	100	6,1	220	0	100	6,1	220	0	100	100	0
1	0	100	6,1	220	60	1100	6,1	220	1000	100	100	0
2	0	100	6,1	220	60	1800	6,0	220	800	1000	100	0
3	0	100	6,1	220	60	1000	6,1	220	900	100	100	0
4	0	100	6,1	220	40	1050	6,1	220	800	250	100	0
5	0	100	6,1	220	40	1150	6,1	220	900	250	100	0
6	0	100	6,1	220	40	1000	6,1	220	900	100	100	0
7	20	600	6,1	220	50	1400	6,0	220	600	800	600	0
8	10	250	6,1	220	40	950	6,1	220	600	350	250	0
9	20	800	6,1	220	40	950	6,1	220	600	350	800	0
10	5	150	6,1	220	60	1400	6,0	220	600	800	150	0
11	5	150	6,1	220	20	300	6,1	220	0	300	150	0
12	10	200	6,1	220	60	1450	6,0	220	600	850	200	0
13	10	200	6,1	220	40	900	6,1	220	600	300	200	0
14	10	200	6,1	220	60	1500	6,0	220	1200	300	200	0
15	10	200	6,1	220	40	800	6,1	220	0	800	200	0
16	5	150	6,1	220	40	900	6,1	220	600	300	150	0
17	5	150	6,1	220	60	1500	6,0	220	1200	300	150	0
18	5	150	6,1	220	60	1400	6,0	220	600	800	150	0
19	0	100	6,1	220	5	150	6,1	220	0	150	100	0
20	0	100	6,1	220	5	150	6,1	220	0	150	100	0
21	0	100	6,1	220	60	1400	6,0	220	600	800	100	0
22	0	100	6,1	220	5	150	6,1	220	0	150	100	0
23	0	100	6,1	220	40	900	6,1	220	600	300	100	0

Генеральный директор




А.К. Шаварин





яч.42	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
яч.44	0	0	0	0	0	0	0	50	50	50	50	50	50	70	70	70	70	50	50	50	50	50	50	50
P, кВт	0	0	0	0	0	0	0	449	449	449	449	449	449	629	629	629	629	449	449	449	449	449	449	449
Q, кВАр	0	0	0	0	0	0	0	278	278	278	278	278	278	390	390	390	390	278	278	278	278	278	278	278
яч.46	40	40	50	50	40	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50
P, кВт	359	359	449	449	359	449	449	449	449	449	449	449	449	449	449	449	449	449	449	449	449	449	449	449
Q, кВАр	223	223	278	278	223	278	278	278	278	278	278	278	278	278	278	278	278	278	278	278	278	278	278	278
яч.48	60	30	20	50	50	50	50	50	70	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20
P, кВт	539	269	180	449	449	449	449	449	629	180	180	180	180	180	180	180	180	180	180	180	180	180	180	180
Q, кВАр	334	167	111	278	278	278	278	278	390	111	111	111	111	111	111	111	111	111	111	111	111	111	111	111

Генеральный директор




А.К. Шаварин

**Замеры напряжения и нагрузок на ГПП-2 за 15.06.2022  
ООО "ЭСР"**

Часы	Трансформатор-1				Трансформатор-2				Нагрузка, кВт			
	I <sub>вн</sub> , А	I <sub>нн</sub> , А	U <sub>вн</sub> , кВ	U <sub>нн</sub> , В	I <sub>вн</sub> , А	I <sub>нн</sub> , А	U <sub>вн</sub> , кВ	U <sub>нн</sub> , В	яч.13	яч.14	яч.35	яч.36
0	0	100	6,1	220	0	100	6,1	220	0	560	115	150
1	0	100	6,1	220	60	1100	6,1	220	0	510	50	100
2	0	100	6,1	220	60	1800	6,0	220	0	440	80	100
3	0	100	6,1	220	60	1000	6,1	220	0	480	80	100
4	0	100	6,1	220	40	1050	6,1	220	0	480	100	100
5	0	100	6,1	220	40	1050	6,1	220	10	500	90	150
6	0	100	6,1	220	40	1000	6,1	220	10	590	140	150
7	20	600	6,1	220	50	1400	6,0	220	200	600	350	300
8	10	250	6,1	220	40	950	6,1	220	250	650	350	300
9	20	800	6,0	220	40	950	6,1	220	200	650	350	250
10	5	150	6,1	220	60	1400	6,0	220	100	600	350	250
11	5	150	6,1	220	20	300	6,1	220	200	650	350	250
12	10	200	6,1	220	60	1450	6,0	220	200	650	350	250
13	10	200	6,1	220	40	900	6,1	220	200	650	350	300
14	10	200	6,1	220	60	1500	6,0	220	150	600	350	200
15	10	200	6,1	220	40	800	6,1	220	150	550	350	200
16	5	150	6,1	220	40	900	6,1	220	150	550	400	200
17	5	150	6,1	220	60	1500	6,0	220	100	550	400	200
18	5	150	6,1	220	60	1400	6,0	220	100	550	400	200
19	0	100	6,1	220	5	150	6,1	220	100	550	350	200
20	0	100	6,1	220	5	150	6,1	220	100	500	350	200
21	0	100	6,1	220	60	1400	6,0	220	100	500	350	200
22	0	100	6,1	220	5	150	6,1	220	100	500	350	200
23	0	100	6,1	220	40	900	6,1	220	100	500	350	200

Генеральный директор



А.К. Шаварин

## Нагрузка по вводным ячейкам ГПП-1 Промтрактор

ООО "ЭСР"

Дата и время	ГПП-1 яч.12 Ввод-1А		ГПП-1 яч.24 Ввод-2А	
	[кВт]	[квар]	[кВт]	[квар]
15.06.2022 1:00	0	0	1012,8	713,6
15.06.2022 2:00	0	0	1001,6	716,8
15.06.2022 3:00	0	0	960	675,2
15.06.2022 4:00	0	0	987,2	716,8
15.06.2022 5:00	0	0	952	720
15.06.2022 6:00	0	0	948,8	670,4
15.06.2022 7:00	0	0	1025,6	721,6
15.06.2022 8:00	0	0	1179,2	868,8
15.06.2022 9:00	0	0	1190,4	902,4
15.06.2022 10:00	0	0	1272	979,2
15.06.2022 11:00	0	0	1276,8	931,2
15.06.2022 12:00	0	0	1291,2	947,2
15.06.2022 13:00	0	0	1318,4	1032
15.06.2022 14:00	0	0	1440	1182,4
15.06.2022 15:00	0	0	1276,8	944
15.06.2022 16:00	0	0	1211,2	944
15.06.2022 17:00	0	0	1078,4	846,4
15.06.2022 18:00	0	0	1131,2	868,8
15.06.2022 19:00	0	0	1009,6	716,8
15.06.2022 20:00	0	0	1009,6	771,2
15.06.2022 21:00	0	0	996,8	742,4
15.06.2022 22:00	0	0	1028,8	739,2
15.06.2022 23:00	0	0	1020,8	718,4
16.06.2022 0:00	0	0	985,6	752
<b>Итого</b>	<b>0</b>	<b>0</b>	<b>76604,8</b>	<b>19820,8</b>

Генеральный директор

А.К. Шаварин




Нарузка по отходящим явкам ГП-1 Промтрактор

ООО "ЭСП"

Дата и время	ГП-1-яч.1А	ГП-1-яч.3	ГП-1-яч.4	ГП-1-яч.5	ГП-1-яч.6	ГП-1-яч.7	ГП-1-яч.8	ГП-1-яч.14	ГП-1-яч.15	ГП-1-яч.17	ГП-1-яч.19	ГП-1-яч.20	ГП-1-яч.21	ГП-1-яч.27	ГП-1-яч.28	ГП-1-яч.29	ГП-1-яч.30	ГП-1-яч.31	ГП-1-яч.32	ГП-1-яч.33	ГП-1-яч.34
	18	126	126	258	0	0	0,8	99,6	0	12	8	49,2	40	18	24	15,6	0	0	15,6	18	15,6
	0	16,8	96	258	0	0	0,8	40,8	0	12	8	49,2	40	18	24	15,6	0	0	14,4	24	15,6
15.06.2022 2:00	0	16,8	126	258	0	0	0,8	28,8	0	12	12	51,6	44	24	18	0	0	4,8	504	24	14,4
15.06.2022 3:00	0	16,8	126	258	0	0	0,8	21,6	0	12	8	46,8	44	18	18	0	0	2,4	456	24	14,4
15.06.2022 4:00	0	16,8	96	258	0	0	0,8	21,6	0	12	12	51,6	44	18	18	0	0	2,4	504	24	14,4
15.06.2022 5:00	0	16,8	96	258	0	0	0,8	21,6	0	12	12	51,6	44	18	18	0	0	2,4	486	24	14,4
15.06.2022 6:00	0	14,4	108	246	0	0	0,8	19,2	0	12	8	44,4	40	24	18	0	0	2,4	474	18	14,4
15.06.2022 7:00	0	18	108	282	0	0	0,8	36	0	12	16	67,2	44	24	18	0	0	2,4	516	18	14,4
15.06.2022 8:00	0	28,8	138	282	0	0	0,8	36	0	12	16	69,6	56	24	18	0	0	2,4	516	18	14,4
15.06.2022 9:00	0	26,4	174	306	0	0	1,6	36	0	16	16	72	64	24	18	0	0	2,4	552	24	14,4
15.06.2022 10:00	0	43,2	192	306	0	0	1,6	63,6	0	16	20	82,8	76	36	18	0	0	2,4	588	18	15,6
15.06.2022 11:00	0	40,8	198	306	0	0	1,6	67,2	0	16	16	80,8	72	36	18	0	0	2,4	552	24	15,6
15.06.2022 12:00	0	39,6	198	294	0	0	1,6	47,2	0	16	16	68,4	72	36	18	0	0	2,4	516	18	14,4
15.06.2022 13:00	0	38,4	210	294	0	0	1,6	47,2	0	16	16	68,4	72	36	18	0	0	2,4	516	18	14,4
15.06.2022 14:00	0	34,8	216	318	0	0	1,6	91,2	0	16	16	82,8	76	36	18	0	0	2,4	588	18	15,6
15.06.2022 15:00	0	26,4	222	288	0	0	1,6	52,8	0	12	16	76,8	56	36	18	0	0	2,4	516	18	14,4
15.06.2022 16:00	0	14,4	168	276	0	0	1,6	48	0	16	16	69,6	52	36	18	0	0	2,4	498	24	15,6
15.06.2022 17:00	0	16,8	180	282	0	0	1,6	73,2	0	12	12	86,4	44	36	18	0	0	2,4	498	24	15,6
15.06.2022 18:00	0	13,2	138	276	0	0	1,6	33,6	0	12	12	86,4	44	36	18	0	0	2,4	498	24	15,6
15.06.2022 19:00	0	12	120	282	0	0	0,8	27,6	0	12	12	58,8	37	40	18	0	0	2,4	462	24	14,4
15.06.2022 20:00	0	10,8	108	264	0	0	0,8	25,2	0	12	12	45,6	36	40	18	0	0	2,4	498	24	15,6
15.06.2022 21:00	0	14,4	126	270	0	0	0,8	25,2	0	12	8	49,2	40	18	18	0	0	2,4	498	24	15,6
15.06.2022 22:00	0	15,6	96	276	0	0	0,8	44,4	0	12	8	64,8	44	18	18	0	0	2,4	486	18	15,6
15.06.2022 23:00	0	16,8	114	276	0	0	0,8	43,2	0	12	12	67,2	44	18	18	0	0	2,4	486	18	15,6
16.06.2022 0:00	0	16,8	90	234	0	0	0,8	43,2	0	12	8	52,8	40	20	18	0	0	2,4	498	18	15,6
Итого	0	528	3438	6678	0	0	27,2	1014	0	201,6	296	1413,6	1176	632	432	0	60	12132	498	355,2	0

Генеральный директор



А.К. Шаврин

## Нагрузка по вводным ячейкам ГПП-3 Промтрактор

ООО "ЭСР"

Дата и время	ГПП-3 яч.29 Ввод-1А		ГПП-3 яч.30 Ввод-1Б		ГПП-3 яч.47 Ввод-2А		ГПП-3 яч.50 Ввод-2Б	
	[кВт]	[квар]	[кВт]	[квар]	[кВт]	[квар]	[кВт]	[квар]
15.06.2022 1:00	1032	780	3360	1452	720	636	768	450
15.06.2022 2:00	996	768	3300	1458	696	612	606	438
15.06.2022 3:00	942	702	3180	1440	726	594	588	420
15.06.2022 4:00	912	714	3030	1422	714	606	582	432
15.06.2022 5:00	930	780	3012	1422	666	606	546	426
15.06.2022 6:00	978	744	2916	1446	558	612	564	438
15.06.2022 7:00	1308	960	3720	2322	858	936	786	576
15.06.2022 8:00	2016	1392	4632	3606	1314	1452	1158	918
15.06.2022 9:00	2214	1560	4908	3786	1398	1566	1206	978
15.06.2022 10:00	2304	1608	5046	3768	1416	1608	1296	972
15.06.2022 11:00	2028	1296	4788	3408	1230	1380	1182	876
15.06.2022 12:00	2142	1452	5052	3936	1380	1572	1314	1038
15.06.2022 13:00	2094	1434	5046	4074	1380	1602	1230	1038
15.06.2022 14:00	2088	1446	4380	4038	1422	1638	1236	960
15.06.2022 15:00	1986	1386	4188	3804	1344	1512	1314	882
15.06.2022 16:00	1914	1248	3468	2712	1068	1128	1200	738
15.06.2022 17:00	1836	1218	3276	2478	978	972	1140	720
15.06.2022 18:00	1704	1092	3216	2196	972	810	1050	672
15.06.2022 19:00	1248	912	2868	1872	864	666	822	558
15.06.2022 20:00	1122	864	2742	1650	864	678	708	486
15.06.2022 21:00	1170	906	2868	1560	876	690	690	474
15.06.2022 22:00	1116	846	2970	1548	858	660	744	486
15.06.2022 23:00	1128	816	3246	1386	864	648	840	480
16.06.2022 0:00	1188	966	3138	1392	846	612	810	450
<b>Итого</b>	<b>36396</b>	<b>25890</b>	<b>88350</b>	<b>58176</b>	<b>24012</b>	<b>23796</b>	<b>22380</b>	<b>15906</b>

Генеральный директор

А.К. Шаварин

